

RE: Discharge of Condition 13 of DM/24/2704



FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>

To ✓ Stefan Galyas

Retention Policy Default 3 year delete (3 years)

This sender FRSWaterandAccess@westsussex.gov.uk is from outside your organisation.

Expires on 10/08/2029

Reply

Reply All

Forward



Tue 11/08/2026 16:16

You don't often get email from frswaterandaccess@westsussex.gov.uk. [Learn why this is important](#)

Dear Stefan,

Provided the fire hydrants indicated on the plan submitted are in place, ready for use and West Sussex Fire & Rescue Service are informed it is ready for use, the fire hydrant condition raised will be met and can be discharged. Unfortunately, on too many occasions WSFRS are not informed when a FH is ready for adoption, which then puts lives and properties at greater risk in the event of a fire.

Regards

Ian



Ian Stocks

Water & Access Manager - Protection

West Sussex Fire & Rescue Service

Office 0330 222 4499 **Mobile** 07921 291051

Web www.westsussex.gov.uk/fire

Email frs.waterandaccess@westsussex.gov.uk

Bognor Regis Fire Station, West Meads Drive, West Sussex, PO19 1BD