

From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
Sent: 10 June 2025 12:38:24 UTC+01:00
To: "planninginfo" <planninginfo@midsussex.gov.uk>
Subject: Planning consultation - DM/24/3104 Sandhill Farm Sandhill Lane Crawley Down
Crawley West Sussex RH10 4LE

FAO: Joanne Fisher

Dear Joanne,

Having viewed the plans for the planning application no. DM/24/3104 for the Temporary agriculturally tied caravan accommodation. Amended plans, BNG metric and application form received 4th and 14th April to amend red line to provide on-site BNG): the nearest fire hydrant for the supply of water for firefighting is 255 metres away, 80-metres further than the 175-metre distance required for a domestic premises. If an alternative water supply for firefighting is to be considered it will need to conform with the details identified in Approved Document-B (AD-B) Volume 1: B5 section 14 and agreed with West Sussex Fire & Rescue Service.

Regards
Ian



Ian Stocks

Water & Access Manager - Protection

West Sussex Fire & Rescue Service

Office 0330 222 4499 **Mobile** 07921 291051

Web www.westsussex.gov.uk/fire

Email frs.waterandaccess@westsussex.gov.uk

Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

My pronouns are he/him/his

[Click here to find out why we use pronouns in our signatures](#)



LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.
