

From: drainage <drainage@midsussex.gov.uk>
Sent: 20 March 2026 14:08:44 UTC+00:00
To: "Andrew Horrell" <Andrew.Horrell@midsussex.gov.uk>
Cc: "drainage" <drainage@midsussex.gov.uk>
Subject: 2026.03.20 Re: DM/25/0463 - Naldretts Farm, Pookbourne Lane, Sayers Common, Hassocks (Discharge of condition nos 3, 4 and 6 relating to planning application)

Dear Andrew,

The Flood Risk and Drainage Team have reviewed the updated information and have the following comments:

Calculations should be provided for the access roads drainage.

Upon receipt of this additional information, we will be able to comment further.

Best Wishes

Flood Risk and Drainage Team
Estate Services and Building Control
Mid Sussex District Council
drainage@midsussex.gov.uk