

From: Paul Carter <PC@bandcarchitecture.co.uk>
Sent: 14 March 2025 16:50:30 UTC+00:00
To: "Peter Davies" <Peter.Davies@midsussex.gov.uk>
Subject: Furzedown Eden Vale DM/25/0182

REF : Furzedown Eden Vale DM/25/0182

Hi Peter,

I hope you are well.

Please see my comment below.

Please can you confirm the materials to be used for the roof of the shed? – Shingles

Additionally, the scale between the elevations and the floor plan seems to be incorrect. The elevations show the front elevation has a width of 3.50 metres however the floor plan shows to have a width of 3.90 metres. Please can this be corrected – the outer line on the floor plan represents the roof projection.

Kind regards

Paul



Paul Carter | Design Director | 077518 78897

3 High Street, East Grinstead, RH19 3AF

www.bandcarchitecture.co.uk



This transmission is confidential and intended solely for the person or organisation to whom it is addressed. Access to this message by any other person is unauthorised. If you are not the intended recipient, any disclosure, copying, distribution or any action taken or omitted to be taken in reliance on it, is prohibited.

Although any attachments to this message have been checked for viruses, it is the responsibility of the recipient to ensure that they have relied on their own virus checker and procedures.

If you receive this transmission in error, please contact the sender and delete the material from your computer.

From: Peter Davies <Peter.Davies@midsussex.gov.uk>

Sent: 14 March 2025 14:36

To: Paul Carter <PC@bandcarchitecture.co.uk>

Subject: Furzedown Eden Vale DM/25/0182

Hi Paul,

Please can you confirm the materials to be used for the roof of the shed?

Additionally, the scale between the elevations and the floor plan seems to be incorrect. The elevations show the front elevation has a width of 3.50 metres however the floor plan shows to have a width of 3.90 metres. Please can this be corrected.

Kind regards

Peter

Peter Davies BSc (Hons)
Trainee Planning Officer
Development Management
Mid Sussex District Council
01444 477193
www.midsussex.gov.uk

Working together for a better Mid Sussex



- SAVE A TREE Only print this email if absolutely necessary.

The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information contained in this email is legally exempt from disclosure, we cannot guarantee that we will not provide the whole or part of this email to a third party making a request for information about the subject matter of this email. This email and any attachments may contain confidential information and is intended only to be seen and used by the named addressees. If you are not the named addressee, any use, disclosure, copying, alteration or forwarding of this email and its attachments is unauthorised. If you have received this email in error please notify the sender immediately by email or by calling +44 (0) 1444 458 166 and remove this email and its attachments from your system. The views expressed within this email and any attachments are not necessarily the views or policies of Mid Sussex District Council. We have taken precautions to minimise the risk of transmitting software viruses, but we advise you to carry out your own virus checks before accessing this email and any attachments. Except where required by law, we shall not be responsible

for any damage, loss or liability of any kind suffered in connection with this email and any attachments, or which may result from reliance on the contents of this email and any attachments.