

From: Martin Landivar <martin@landivar-architects.com>
Sent: 24 August 2026 12:25:13 UTC+01:00
To: "Susan Dubberley" <susan.dubberley@midsussex.gov.uk>; "Emily Wade" <Emily.Wade@midsussex.gov.uk>
Subject: Castle Inn DM/26/0200

Hi Sue & Emily,

It was good to see you last week on-site and following on from our conversation, please find attached two photographs of an additional lime mortar pointing sample panel. We requested that the pointing is slightly recessed into the joint by a couple of millimeters, so as to provide a clean finish, without bleeding onto the brick itself.

I think it works well. Please let me know if you're happy with us to proceed with this approach and if you have any queries, please do not hesitate to contact me.

With kind regards,

Martin Landivar
BA (Hons) PG - DIP ARCH, ARB, RIBA

T: 01273 739590
M: +44 7919105614

LANDÍVAR ARCHITECTS

Landívar Architects Ltd
The Workshop
Unit 3, 29-42 Windsor Street
Brighton
BN1 1RJ



