

From: Anna Tidey
Sent: 07 January 2025 10:33:45 UTC+00:00
To: "Jonathan Talley" <jon@jtalimited.co.uk>
Subject: RE: DM/24/2933 - 23 Meadow Drive Lindfield Haywards Heath West Sussex RH16 2RS

Good Morning Jonathan

I have to take advice from my Drainage colleagues regarding potential flooding issues seriously in the determination of an application.

As it stands I would have to recommend the application is refused, unless they can be convinced, with consideration of the requested evidence, that there would not be an adverse effect.

Please can you advise me how your clients wish to proceed, or if they would prefer to Withdraw the application? As you are aware I have yet to arrange my site visit.

Whilst writing I should advise you that I shall be on a period of leave from the end of 10th January until 21st January 2025.

Regards
Anna Tidey
Planning Officer

Submit your planning application online.
<http://www.planningportal.gov.uk>

Anna Tidey BA(Hons) MPhil MRTPI
Planning Officer
Development Management

Tel: +44 (0)1444 477342
anna.tidey@midsussex.gov.uk <http://www.midsussex.gov.uk>



Working together for a Better Mid Sussex.



- SAVE A TREE Only print this email if absolutely necessary.

From: Jonathan Talley <jon@jtalimited.co.uk>

Sent: 06 January 2025 15:17

To: Anna Tidey <anna.tidey@midsussex.gov.uk>

Subject: Re: DM/24/2933 - 23 Meadow Drive Lindfield Haywards Heath West Sussex RH16 2RS

Thanks Anna

Can I assume if you determined it without the modeling then it would be refused?

Is this the only point of concern in regards to the application as there is a cost to providing this surface water modelling.

Kind regards

Jon

Jonathan Talley - Director

The Office will be closed from 5pm Thursday 19th December reopening on Tuesday 7th January
- Happy Christmas

For and on behalf of Jonathan Talley Architects Limited

email jon@jtalimited.co.uk

telephone 07956 870 019

website www.jtalimited.co.uk

Follow us on [Facebook](#) and [Instagram](#)

Jonathan Talley Architects Limited is a Registered Company in England and Wales Reg. No. 13707071.

Registered Office 16 Coniston Avenue, Haywards Heath, Mid Sussex, RH17 5LF

Disclaimer: This email contains confidential information and is intended only for the addressee. If you are not the addressee, you should not disseminate, distribute or copy this email. Please notify JTA immediately by email if you received this email by mistake and delete this email from your system. Email transmissions cannot be guaranteed to be secure or error-free as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete or contain viruses. The sender cannot take responsibility for any loss or damage arising from the use of this email or attachments. All views and opinions expressed on their email message are the author's personal opinions and do not represent that of the company. No liability can be held for any damages, however caused, to any recipients of this message.

On Mon, 6 Jan 2025 at 14:47, Anna Tidey <anna.tidey@midsussex.gov.uk> wrote:

Good afternoon Jon

Thank you for your email, and Happy New Year.

Yes, what has been requested is **surface water modelling** information. This needs to demonstrate 'that the development design ensures that, for the 1:100 year + climate change event:

- Site users are safe in the event of a flood
- There is no loss of floodplain storage
- There is no impedance of overland flows
- There is no increase in flood risk '

Please confirm whether your clients will provide this supporting information? If they are not agreeable I can determine the application as submitted, or you can Withdraw the application in writing. I look forward to hearing from you.

Regards

Anna Tidey

Planning Officer

Submit your planning application online.

<http://www.planningportal.gov.uk>

Anna Tidey BA(Hons) MPhil MRTPI
Planning Officer
Development Management

Tel: +44 (0)1444 477342

anna.tidey@midsussex.gov.uk

<http://www.midsussex.gov.uk>



Working together for a Better Mid Sussex.



- SAVE A TREE Only print this email if absolutely necessary.

From: Jonathan Talley <jon@jtalimited.co.uk>

Sent: 06 January 2025 11:17

To: Anna Tidey <anna.tidey@midsussex.gov.uk>

Subject: Re: DM/24/2933 - 23 Meadow Drive Lindfield Haywards Heath West Sussex RH16 2RS

Hi Anna

I hope you are well and had a good break over Christmas

Can you just confirm what you are requiring from us? Is it a surface water modeling report?

Thanks

Kind regards

Jon

Jonathan Talley - Director

The Office will be closed from 5pm Thursday 19th December reopening on Tuesday 7th January - Happy Christmas

For and on behalf of Jonathan Talley Architects Limited

email jon@jtalimited.co.uk

telephone 07956 870 019

website www.jtalimited.co.uk

Follow us on [Facebook](#) and [Instagram](#)

Jonathan Talley Architects Limited is a Registered Company in England and Wales Reg. No. 13707071.

Registered Office 16 Coniston Avenue, Haywards Heath, Mid Sussex, RH17 5LF

Disclaimer: This email contains confidential information and is intended only for the addressee. If you are not the addressee, you should not disseminate, distribute or copy this email. Please notify JTA immediately by email if you received this email by mistake and delete this email from your system. Email transmissions cannot be guaranteed to be secure or error-free as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete or contain viruses. The sender cannot take responsibility for any loss or damage arising from the use of this email or attachments. All views and opinions expressed on their email message are the author's personal opinions and do not represent that of the company. No liability can be held for any damages, however caused, to any recipients of this message.

On Mon, 23 Dec 2024 at 09:23, Anna Tidey <anna.tidey@midsussex.gov.uk> wrote:

Good morning Jonathan

Following on from your recent communication I realise that you may not receive this email until the New Year. I received the attached consultation response from the Flood Risk and Drainage Team regarding this application on Friday last week.

As you can see they have raised an objection and request the submission of further supporting information. They state that they would have no objection to the scheme if surface water modelling can be provided.

I await your confirmation whether your clients will wish to provide this supporting information. If not I can determine the application as submitted, or the application can be Withdrawn in writing.

I look forward to hearing from you.

Regards

Anna Tidey

Planning Officer

Submit your planning application online.

<http://www.planningportal.gov.uk>

Anna Tidey BA(Hons) MPhil MRTPI

Planning Officer

Development Management

Tel: +44 (0)1444 477342

anna.tidey@midsussex.gov.uk

<http://www.midsussex.gov.uk>



Working together for a Better Mid Sussex.



- SAVE A TREE Only print this email if absolutely necessary.

From: drainage <drainage@midsussex.gov.uk>
Sent: 20 December 2024 17:26
To: Anna Tidey <anna.tidey@midsussex.gov.uk>
Cc: drainage <drainage@midsussex.gov.uk>
Subject: 2024.12.20 Re: DM/24/2933 - App - Minor - 23 Meadow Drive Lindfield Haywards Heath West Sussex RH16 2RS

Dear Anna,

Thank you for consulting the Flood Risk and Drainage Team with regard to the above application. We understand the application is for demolition of existing garage and erection of a two storey rear and side extension and new front porch. The Flood Risk Assessment provided by the Applicant has been reviewed, and we would comment as follows:

The site is in flood zone 1 and is at low fluvial flood risk (risk of flooding from Main Rivers). The site is shown to be at very low, low, medium, and high surface water flood risk (comparable to flood zone 3b, 3a, 2 and 1).

The proposed development site is located within an area impacted by the 1:30, 1:100 and 1:1,000 flood events (high, medium, and low surface water flood risk). Following the approach set out under the NPPF for assessing fluvial flood risk (flood zones) this area would be considered consistent with Flood Zone 3b (1:30 extent), Flood Zone 3a (1:100 extent), and Flood Zone 2 (1:1000 extent).


Annual exceedance	Flood Zone	Surface Water Flood Risk
Greater than 3.3% (>1:30-year)	3b	High
Between 1% and 3.3% (1:100-year and 1:30-year)	3a	Medium
Between 0.1% and 1% (1:1,000-year and 1:100-year)	2	Low
Less than 0.1% (<1:1,000-year)	1	Very Low

The PPG states that the design flood event for surface water is the 1:100 plus an allowance for climate change which is the same as for river flood events.

The Mid Sussex's Strategic Flood Risk Assessment provides guidance on when areas should be considered functional flood plain (Flood Zone 3b), these are:

- All areas within present-day Flood Zone 3
- Any land impacted by the 1:30 flood extent or designed to flood during a 1:100 event, and
- Areas of high surface water flood risk (1:30 extent)

Based on the latest guidance that all sources of flooding should be considered consistently the site meets one of the reasons an area would be considered functional floodplain (Flood Zone 3b); it's location within the 1:30 surface water flood extent.



The proposed development is a 'more vulnerable' development.

It is the Flood Risk and Drainage Team's findings that, following the latest guidance on assessing flood risk the site is located within the equivalent of Flood Zone 3b

(1:30 flood extent) and the proposed development is a more vulnerable development.

As per the Environment Agency standing advice for minor extensions, development within the 1:30 flood extent is not permissible. In the event that the proposal is outside of this extent then additional resistance and resilience mitigation will need to be evidenced at this location, as this development is classified as 'more vulnerable'

In addition, the Flood and Drainage Team would have no objection to the scheme if surface water modelling can be provided which demonstrates that the development design ensures that, for the 1:100 year + climate change event:

- Site users are safe in the event of a flood
- There is no loss of floodplain storage
- There is no impedance of overland flows
- There is no increase in flood risk

Receipt of the requested additional information does not mean further information will not be requested, nor does it guarantee that the Flood Risk and Drainage Team will not object to the development. Neither does it prevent the team from recommending a flood risk or drainage condition.

Best Wishes

Flood Risk and Drainage Team
Estate Services & Building Control
Mid Sussex District Council
drainage@midsussex.gov.uk

The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information contained in this email is legally exempt from disclosure, we cannot guarantee that we will not provide the whole or part of this email to a third party making a request for information about the subject matter of this email. This email and any attachments may contain confidential information and is intended only to be seen and used by the named addressees. If you are not the named addressee, any use, disclosure, copying, alteration or forwarding of this email and its attachments is unauthorised. If you have received this email in error please notify the sender immediately by email or by calling +44 (0) 1444 458 166 and remove this email and its attachments from your system. The views expressed within this email and any attachments are not necessarily the views or policies of Mid Sussex District Council. We have taken precautions to minimise the risk of transmitting software viruses, but we advise you to carry out your own virus checks before accessing this email and any attachments. Except where required by law, we shall not be responsible for any damage, loss or liability of any kind suffered in connection with this email and any

attachments, or which may result from reliance on the contents of this email and any attachments.

The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information contained in this email is legally exempt from disclosure, we cannot guarantee that we will not provide the whole or part of this email to a third party making a request for information about the subject matter of this email. This email and any attachments may contain confidential information and is intended only to be seen and used by the named addressees. If you are not the named addressee, any use, disclosure, copying, alteration or forwarding of this email and its attachments is unauthorised. If you have received this email in error please notify the sender immediately by email or by calling +44 (0) 1444 458 166 and remove this email and its attachments from your system. The views expressed within this email and any attachments are not necessarily the views or policies of Mid Sussex District Council. We have taken precautions to minimise the risk of transmitting software viruses, but we advise you to carry out your own virus checks before accessing this email and any attachments. Except where required by law, we shall not be responsible for any damage, loss or liability of any kind suffered in connection with this email and any attachments, or which may result from reliance on the contents of this email and any attachments.