

From: drainage <drainage@midsussex.gov.uk>
Sent: 28 August 2025 06:59:17 UTC+01:00
To: "Katherine Williams" <Katherine.Williams@midsussex.gov.uk>
Cc: "drainage" <drainage@midsussex.gov.uk>
Subject: 2025.08.28 DM/25/1021 - Hatchgate Cottage Hatchgate Lane Cuckfield
Haywards Heath West Sussex RH17 5DU

Dear Katherine,

Our engineers have reviewed the above application, for completeness, the applicant should update the drainage calculations for the permeable Macadam paving at S10 so the IL reflects the details on the layout and cross section.

Best Wishes

Flood Risk and Drainage Team
Estate Services and Building Control
Mid Sussex District Council
drainage@midsussex.gov.uk