

From: Eleanor Read <Eleanor.Read@westsussex.gov.uk>
Sent: 09 January 2025 18:33:43 UTC+01:00
To: "David Major" <david.major@ramboll.co.uk>
Cc: "Anthony Guay" <Ant.Guay@ramboll.co.uk>
Subject: RE: Crawley Down/Bolney - Pre-app written responses

Hi David,
I can confirm 40% is the allowance for Crawley Down, apologies.
Regards,
Ellie


Eleanor Read
Flood Risk Management Officer | Flood Risk Management Team
West Sussex County Council, Ground Floor, Northleigh, County Hall, Chichester PO19 1RH
Internal Phone: 227048 | External Phone: 03302 227048
Email: eleanor.read@westsussex.gov.uk | Web: www.westsussex.gov.uk

Classification: Confidential

From: David Major
Sent: Tuesday, December 17, 2024 4:11 PM
To: Eleanor Read
Cc: Anthony Guay
Subject: RE: Crawley Down/Bolney - Pre-app written responses

****EXTERNAL****

Hi Eleanor,
Thanks for the below.
Specifically on Crawley you state that the required CC allowance is 45% however when we reviewed the EA website it suggested the allowance was 40% for the site. See below:



Kind regards

David Major

BSc (Hons), MSc, MCIWEM
Consultant
1622761 - Water
D +44 2380 817672
M +44 7866 055808
david.major@ramboll.co.uk

Ramboll
Twenty3
Brunswick Place
Southampton
SO15 2AQ
<https://uk.ramboll.com/environment-and-health>

Ramboll UK Limited Registered in England & Wales Company No: 03659970
Registered office: 240 Blackfriars Road, London SE1 8NW

Classification: Confidential

From: Eleanor Read <Eleanor.Read@westsussex.gov.uk>

Sent: Monday, December 16, 2024 5:08 PM

To: David Major <david.major@ramboll.co.uk>

Cc: Anthony Guay <Ant.Guay@ramboll.co.uk>

Subject: RE: Crawley Down/Bolney - Pre-app written responses

Hi David,

Please see both responses attached. As mentioned in meeting I'm happy to review any changes/further work until applications are submitted. I'm going to close the cases on our system but still very much here to help/advise.

I couldn't remember which one had the cycle path and community centre as the full application-the proforma says what is required for outline vs full. Happy to discuss that bit in more detail in the New Year.

I'm on leave between midday Thursday and the 2nd Jan.

Kind regards,

Ellie

Eleanor Read

Flood Risk Management Officer | Flood Risk Management Team
West Sussex County Council, Ground Floor, Northleigh, County Hall, Chichester PO19 1RH
Internal Phone: 227048 | External Phone: 03302 227048
Email: eleanor.read@westsussex.gov.uk | Web: www.westsussex.gov.uk

Classification: Confidential

From: David Major <david.major@ramboll.co.uk>

Sent: Friday, December 6, 2024 9:25 AM

To: Eleanor Read <Eleanor.Read@westsussex.gov.uk>

Cc: Anthony Guay <Ant.Guay@ramboll.co.uk>

Subject: Crawley Down/Bolney - Pre-app written responses

****EXTERNAL****

Hi Eleanor,

Thanks very much for your time last week regarding the two separate meetings for the two sites at Crawley Down and Bolney. It was very useful for us.

Regarding the formal written responses do you have an estimate for when these are likely to be ready? Apologies as we're a little tight for time ahead of Christmas and we hoped to send you updated reports prior to submission (within which we hope to append notes of your written responses).

Kind regards

David Major

BSc (Hons), MSc, MCIWEM

Consultant

1622761 - Water

D +44 2380 817672

M +44 7866 055808

david.major@ramboll.co.uk

Ramboll

Twenty3

Brunswick Place

Southampton

SO15 2AQ

<https://uk.ramboll.com/environment-and-health>

Ramboll UK Limited Registered in England & Wales Company No: 03659970

Registered office: 240 Blackfriars Road, London SE1 8NW

Classification: Confidential

CAUTION: This email originated from outside of the organisation. Do not click links or open attachments unless you recognise the sender and know the content is safe.

LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.

CAUTION: This email originated from outside of the organisation. Do not click links or open attachments unless you recognise the sender and know the content is safe.