

From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
Sent: 07 May 2026 15:44:43 UTC+01:00
To: "planninginfo" <planninginfo@midsussex.gov.uk>
Subject: Discharge of FH Condition - DM/24/3077 Sussex House Perrymount Road
Haywards Heath West Sussex RH16 1DN

FAO: Susan Dubberley

Dear Susan,

Following consultation with South-East Water, West Sussex Fire & Rescue Service have now adopted a fire hydrant within 90m of the change of use for Sussex House, therefore the fire hydrant condition raised for this application has now been met and the fire hydrant condition can be discharged.

Kind regards
Ian



Ian Stocks

Water & Access Manager - Protection


West Sussex Fire & Rescue Service

Office 0330 222 4499 **Mobile** 07921 291051

Web www.westsussex.gov.uk/fire

Email frswaterandaccess@westsussex.gov.uk

Bognor Regis Fire Station, West Meads Drive, West Sussex, PO21
5TB



LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.
