

From: Emma Rivett <Emma.Rivett@midsussex.gov.uk>
Sent: 23 May 2025 11:51:54 UTC+01:00
To: "Stefan Galyas" <Stefan.Galyas@midsussex.gov.uk>
Subject: DM/25/0672 - 46 Dale Avenue, Hassocks

Dear Stefan,

I have reviewed the Arboricultural Impact Assessment (AIA) for this proposal and would prefer to see an Arboricultural Method Statement (AMS), as described in the AIA. An incursion into a Category B tree's root protection area should require an AMS.

Please could you request an AMS?

Many thanks.

Emma

Emma Rivett
Assistant Tree Officer-Development Management
www.midsussex.gov.uk

Working together for a better Mid Sussex