

From: Scott@EllisdonArchitecturalAssociates.co.uk
<scott@ellisdonarchitecturalassociates.co.uk>
Sent: 02 September 2026 08:49:19 UTC+01:00
To: "Anna Tidey" <anna.tidey@midsussex.gov.uk>
Cc: "Jane Cooper" <Jane.Cooper@midsussex.gov.uk>; "Cameron Pardue" <CameronPardue@hotmail.com>
Subject: Re: FW: Request for further information/EHO comments re DM/26/1940 - Air conditioning unit - 40 Mill Green Road Haywards Heath West Sussex RH16 1XQ
Attachments: Mill Green Road_Additional Acoustic Information.pdf

Morning Anna,

Please see the attachment. I think I have addressed the areas of additional information; however, please come back to us if further clarification is required.

Many Thanks,

Scott Ellisdon
BA (hons) Architecture
HNC Technical Construction & Management

M: 07828 189525

W: www.EllisdonArchitecturalAssociates.co.uk

E: Scott@EllisdonArchitecturalAssociates.co.uk

COMPANY NUMBER: 13380160

Double O Architectural Management LTD

(Trading as Ellisdon Architectural Associates)

****** Please note that during the school summer holidays, from 22nd July to 7th September, my working hours will be Monday to Thursday, 6:30am to 6:00pm. I will not be easily contactable on Fridays during this period. ******



On Thu, Aug 27, 2026 at 10:24 AM Anna Tidey <anna.tidey@midsussex.gov.uk> wrote:

Good morning Scott

Please see the EHO response from Jane Cooper (email below) for this application.

Jane has recommended that the application should be supported by additional acoustic information, see page 13 of the attached Advice Document.

I have picked out the relevant section, which I have reproduced below for your assistance:

‘Small scale developments, such as a single extraction unit or air conditioning unit may not always require a noise report. However in order to help the LPA to decide whether it is likely to conform to an appropriate sound level, the

following information should be submitted to the LPA prior to the submission of the formal planning application as this will help it determine whether a full noise report will be required to be submitted with the planning application:

- The proposed hours and days of operation of any potentially noisy equipment.*
- The sound power levels of the equipment/plant to be installed or sound pressure levels at a specified distance, in decibels dB(A), (which can be obtained from the manufacturers specifications).*

- Details of where the equipment will be placed i.e. within or outside of the building, marked on a scale plan.

- Details of any noise mitigation measures, for example the fitting of silencers or sound insulation. Predicted noise levels at the noise sensitive receptor to be provided in dB(A).

- Distance away from noise sensitive receptors and the nature of these premises (e.g. offices, residential etc.).'

Please can this additional information be provided and I will reconsult Jane for her comments.

Regards

Anna

Submit your planning application online.

<http://www.planningportal.gov.uk>

Anna Tidey BA(Hons) MPhil MRTPI

Planning Officer

Development Management

Tel: [+44 \(0\)1444 477342](tel:+441444477342)

anna.tidey@midsussex.gov.uk <http://www.midsussex.gov.uk>



Working together for a Better Mid Sussex.



- **SAVE A TREE** Only print this email if absolutely necessary.

From: Jane Cooper <Jane.Cooper@midsussex.gov.uk>
Sent: 26 August 2026 15:15
To: Anna Tidey <anna.tidey@midsussex.gov.uk>
Subject: DM/26/1940 Air conditioning unit

Hi Anna,

The applicant may need to submit an acoustic report, but if they provide the information outlined on page 13 of the Planning Noise Advice Document Sussex dated November 2023 this might suffice.

Please can you let the applicant know.

Thanks,

Jane Cooper

Environmental Health Officer

Environmental Health

Tel: [+44 \(0\)1444 477437](tel:+44(0)1444477437)

Email: jane.cooper@midsussex.gov.uk

Website: www.midsussex.gov.uk



“Working together for a better Mid Sussex”

The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information contained in this email is legally exempt from disclosure, we cannot guarantee that we will not provide the whole or part of this email to a third party making a request for information about the subject matter of this email. This email and any attachments may contain confidential information and is intended only to be seen and used by the named addressees. If you are not the named addressee, any use, disclosure, copying, alteration or forwarding of this email and its attachments is unauthorised. If you have received this email in error please notify the sender immediately by email or by calling [+44 \(0\) 1444 458 166](tel:+441444458166) and remove this email and its attachments from your system. The views expressed within this email and any attachments are not necessarily the views or policies of Mid Sussex District Council. We have taken precautions to minimise the risk of transmitting software viruses, but we advise you to carry out your own virus checks before accessing this email and any attachments. Except where required by law, we shall not be responsible for any damage, loss or liability of any kind suffered in connection with this email and any attachments, or which may result from reliance on the contents of this email and any attachments.