

From: Jane Cooper <Jane.Cooper@midsussex.gov.uk>
Sent: 09 October 2026 10:51:10 UTC+01:00
To: "Joanne Fisher" <Joanne.Fisher@midsussex.gov.uk>
Subject: DM/26/2300

Discharge of planning condition number 7 relating to planning application DM/22/2303

Hi Jo,

I accept that to meet accepted internal noise levels, some rooms to this development will need to keep windows closed. Mitigation in terms of enhanced glazing and alternate means of ventilation have therefore been proposed.

I would however like to clarify a couple of points in the Noise Assessment produced by Acoustic South East dated 18/09/2026:

In section 9.1 I think there is a typo: *Please also note the requirements regarding openable glazing **behind** the louvred vent.* Could this be corrected if this is the case.

In section 9.2 the consultant has recommended that MVHR units should be as quiet as possible, suggesting a limit for mechanical services noise of around 24-26 dB (A). Can the developer please confirm the make and model of the units that will be installed here, and that they will comply with this recommendation.

Can the applicant also confirm that the proposed DUCO acoustic panels 500 are closable.

Thank you,

Kind regards,

Jane Cooper
Environmental Health Officer
Environmental Health
Tel: +44 (0)1444 477437
Email: jane.cooper@midsussex.gov.uk
Website: www.midsussex.gov.uk



"Working together for a better Mid Sussex"