



**MID SUSSEX
DISTRICT COUNCIL**

Oaklands Road, Haywards Heath, West Sussex RH16 1SS

Switchboard: 01444 458166
DX 300320 Haywards Heath 1

Fax: 01444 477464
www.midsussex.gov.uk

Date: 06 October 2026

Anna Tidey
Mid Sussex District Council
Oaklands Road
Haywards Heath
West Sussex
RH16 1SS

Dear Anna,

RE: DM/26/2266– 30 Cantelupe Road East Grinstead West Sussex RH19 3BJ

Thank you for your consultation on the above site. We have reviewed the application and information relating to drainage and flood risk and wish to make the following comments.

The applicant is applying for the proposed conversion of a ground floor vacant commercial property into residential use, dividing into 1x one bedroom flat and 1x studio flat.

The site is at low risk of flooding from all sources and the proposed development will be reducing the footprint of the building. Therefore, following a review of the submitted information and due to the site, size, location, and type of development **we have no objection on surface water and drainage grounds.**

Yours sincerely,

Flood Risk and Drainage Team

Mid Sussex District Council



Awarded for excellence