

From: Richard Butler <Richard.Butler@theplanningbureau.ltd.uk>
Sent: 02 April 2025 21:40:52 UTC+01:00
To: "Joanne Fisher" <Joanne.Fisher@midsussex.gov.uk>
Subject: FW: DM/25/0465 - Maxwellton House, Haywards Heath
Attachments: LSE-2780-04-A-0401_Proposed Elevations 01 02.pdf, LSE-2780-04-A-0402_Proposed Elevations 03 04.pdf, LSE-2780-04-A-0220_Ground Floor General Arrangement Plan.pdf

Hi Joanne,

Please see attached and in red below, response to your comments received last week.

Kind regards,

Richard Butler
Senior Planning Associate

The Planning Bureau Limited

Bournemouth • Coventry • **Hatfield** • Manchester • Ringwood • York
Address: Prospect House, 85 Great North Road, Hatfield, AL9 5DA
Mobile: 07557002144

Working on behalf of:

McCarthy Stone

London South East

W: mccarthystone.co.uk

Prospect House, 85 Great North Road, Hatfield, AL9 5DA

[Charitable Foundation](#) | [LinkedIn](#) | [Facebook](#)



From: Joanne Fisher <Joanne.Fisher@midsussex.gov.uk>
Sent: 19 March 2025 17:04
To: Richard Butler <Richard.Butler@theplanningbureau.ltd.uk>
Subject: DM/25/0465 - Maxwellton House, Haywards Heath

Dear Richard,


Ref: **DM/25/0465**

Proposal: Discharge of planning conditions 6, 7, 8, 17 and 18 relating to planning application DM/22/2218.

Location: Site Of Former Maxwellton House, 41 - 43 Boltro Road, Haywards Heath, West Sussex

I refer to the above application currently under consideration.

I am currently going through the details submitted and it has come to my attention that the submitted drawing LSE-2780-04-A-0402 – Proposed elevations 03 04 will not open, and comes up with the following message: **Attached**



Please can you check this file and re-send it so that it can be taken into consideration in the determination of the condition's application.

In addition, please find my initial comments in relation to the following conditions which need further information or clarification:

Condition 6 – materials

The submitted schedule of materials appears to be acceptable. However, the submitted proposed elevations have not been annotated to explain the location / differences to the 3 types of brick and the 2 types of cladding which are proposed to the building. The condition also requires details of materials/finishes to be provided for the balconies. Please can this also be clarified. **Marked in red in black box**

Condition 7 – front elevation showing the position of the light brick panel

You refer to the proposed elevation plans which accompany the application. However, these have not been annotated to show the location of the light brick panels. **Marked in red with black box**

In addition, these elevations show external vents which were not shown in the originally approved elevations. Please can you provide details of these vents and whether they are to be brick or upvc? Also why are so many needed?

Condition 8 – Brick detailing and elevation features

Having had an initial review of the plans submitted, I have a few queries which need to be clarified / further detail provided:

- the shadow is not shown for the recessed brick panels, and this looks boxed in **Bricks are recessed by 20mm**
- the rainwater is not shown, and it appears that this is boxed in – how does this work on all levels? **We have internal & external drainage, shown on the elevations.**
- the steel beam seems to be exposed and there is not enough information on the external colour / treatment of this. The approved drawings suggest that this has been clad (there is no

shadow from the beam profile on the elevations / CGI of the approved drawings attached to the permission). ? Not sure what this means, could you elaborate.

- The collection of rainwater from the balcony is not explained. We would expect water to be collected in the balcony and redirected to the rainwater downpipe hidden in the column to prevent the soffit panel from being stained or damaged. Rainwater to the balconies are collected in a hidden downpipe

Condition 17- cycle parking

Your covering letter and description refers to this condition being part of consideration, however, the covering letter does not provide which plans have been submitted to deal with this condition. Please can this be clarified and if necessary, the relevant plans be submitted. In addition, details on the type of cycle stands / elevations of the stores need to be provided. Shown on ground floor plan

Please note that I am still going thorough the details provided for all the conditions and further information/clarification may be provided from that already submitted and further requested.


I look forward to hearing from you in respect of the above.

Kind regards

Joanne

Joanne Fisher BSc (Hons), MATP, MRTPI
Team Leader Applications
Development Management
Tel: 01444 477330
joanne.fisher@midsussex.gov.uk
www.midsussex.gov.uk

Working together for a Better Mid Sussex.



The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information contained in this email is legally exempt from disclosure, we cannot guarantee that we will not provide the whole or part of this email to a third party making a request for information about the subject matter of this email. This email and any attachments may contain confidential information and is intended only to be seen and used by the named addressees. If you

are not the named addressee, any use, disclosure, copying, alteration or forwarding of this email and its attachments is unauthorised. If you have received this email in error please notify the sender immediately by email or by calling +44 (0) 1444 458 166 and remove this email and its attachments from your system. The views expressed within this email and any attachments are not necessarily the views or policies of Mid Sussex District Council. We have taken precautions to minimise the risk of transmitting software viruses, but we advise you to carry out your own virus checks before accessing this email and any attachments. Except where required by law, we shall not be responsible for any damage, loss or liability of any kind suffered in connection with this email and any attachments, or which may result from reliance on the contents of this email and any attachments.

Disclaimer – The information in this e-mail and any attachments is confidential and may be legally privileged and protected by law. If you have received it in error please notify us immediately and then delete it. Unauthorised use, dissemination, distribution, publication or copying of this communication is prohibited. You should carry out your own virus checks before opening any attachment. The Planning Bureau accepts no liability for any loss or damage which may be caused by software viruses. The Planning Bureau Limited. Registered in England and Wales No. 2207050. Registered Office: 4th Floor, 100 Holdenhurst Road, Bournemouth, Dorset, BH8 8AQ.