

From: drainage <drainage@midsussex.gov.uk>
Sent: 04 March 2026 14:20:37 UTC+00:00
To: "Stuart Malcolm" <Stuart.Malcolm@midsussex.gov.uk>
Cc: "drainage" <drainage@midsussex.gov.uk>
Subject: 2026.03.04 Re: DM/26/0316 - Playing Fields North Of Headmasters House And Westfield, Hurstpierpoint College, College Lane,

Dear Stuart,

The Flood Risk and Drainage Team have reviewed the submitted information and have the following comments:

It is proposed for surface water to be discharged via a soakaway. It is proposed for foul water to be discharged via a package treatment plant which discharges to a watercourse.

The text on the location plan is not legible.

The submitted information is considered insufficient to address the drainage condition requirements.

The Application should refer to the MSDC Detailed Drainage Design Information Guide for Discharge of Condition Stage <https://www.midsussex.gov.uk/media/yyxere1u/msdc002-detailed-drainage-design-checklist-v20-issued-071125.pdf> for further guidance.

Following receipt of the updated information, the team will be able to provide a more formal consultation response.

Best Wishes

Flood Risk and Drainage Team
Estate Services and Building Control
Mid Sussex District Council
drainage@midsussex.gov.uk