

From: drainage <drainage@midsussex.gov.uk>
Sent: 04 March 2026 14:13:20 UTC+00:00
To: "Joanne Fisher" <Joanne.Fisher@midsussex.gov.uk>
Cc: "drainage" <drainage@midsussex.gov.uk>
Subject: 2026.03.04 Re: DM/25/1535 - Twinham

Dear Joanne,

The Flood Risk and Drainage Team have reviewed the updated information from GTA Civils:

The updated calculations and cross-sections indicate that the soil layer would still need to be relied upon to provide attenuation storage. This is not considered acceptable.

Upon receipt of ammended information, we will be able to comment further.

Best Wishes

Flood Risk and Drainage Team
Estate Services and Building Control
Mid Sussex District Council
drainage@midsussex.gov.uk