

From: Emma Rivett <Emma.Rivett@midsussex.gov.uk>
Sent: 19 March 2025 11:02:08 UTC+00:00
To: "Katherine Williams" <Katherine.Williams@midsussex.gov.uk>
Subject: DM/25/0379 Burgess Hill Burial Ground, Jane Murray Way, Burgess Hill

Dear Katherine,

I have reviewed the Tree Survey and Impact Assessment, and I object to these variations.

The trees are important for screening, and particularly T9, a category A oak tree, has an incursion into the RPA of above the recommended limit from BS5837. Once the storage yard is established, we would have no control of what could be stored within the RPA of that tree and so, could not prevent damage or harm being caused to that tree. That could be detrimental to the tree and would be contrary to DP37 of the Mid Sussex District Plan 2014-2031.

Kind regards

Emma

Emma Rivett
Assistant Tree Officer-Development Management
www.midsussex.gov.uk

Working together for a better Mid Sussex