

From: Tracy Perry <Tracy@jamesclague.co.uk>
Sent: 28 November 2025 13:05:32 UTC+00:00
To: "Emily Wade" <emily.wade@midsussex.gov.uk>
Subject: DM/25/0915 Condition 2 joinery

Hi Emily,

The applicant has confirmed the joinery details previously submitted can be single glazed with traditional diamond leaded lights to match the existing pattern. I attach a joinery detail based on the manufacturer's profiles to include traditional single glazed leaded lights. I understand these can be reinforced with horizontal saddle bars welded to the lead comes and fixed to the internal face of the door and sidelight frames.

I trust these details are acceptable and sufficient to discharge the condition?

Kind regards,



Tracy Perry
y
Associate
James Clague Architects

01227 649073
Tracy@jamesclague.co.uk
www.jamesclague.co.uk
Latchmere House, 26 Watling Street, Canterbury, Kent, CT1 2UD

James Clague Architects is a limited company registered in England & Wales. Registered Number: 08664802. Registered Office Address: 27 Camburgh House, New Dover Road, Canterbury, Kent, CT1 3DN. This e-mail is confidential to the intended recipient. If you have received it in error, please notify the sender and delete it from your system. Any unauthorised use, disclosure, or copying is not permitted. Precautions have been taken to minimise the risk of viruses, but no liability is accepted for any damage caused by any virus transmitted by this e-mail.