

From: planninginfo@midsussex.gov.uk <planninginfo@midsussex.gov.uk>
Sent: 18 September 2025 11:42:11 UTC+01:00
To: "planninginfo" <planninginfo@midsussex.gov.uk>
Subject: Mid Sussex DC - Online Register - Consultee Comments for Planning Application
DM/25/2258

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 18/09/2025 11:42 AM from Mr Nick Bennett on behalf of Environmental Protection.

Application Summary

Reference:	DM/25/2258
Address:	Land Adjacent To Rowan East Of Turners Hill Road Crawley Down West Sussex
Proposal:	Discharge of condtion 18 relating to planning permission DM/23/2961.
Case Officer:	Susan Dubberley

[Click for further information](#)

Comments Details

Comments:	The submitted lighting plan does not include the required information. However, if the timing of the lights turning on were changed from 6am to 7am this would mean that there is no risk of the lighting breaching the curfew limits. Accordingly, please could the applicants either confirm amendment of the timings, or submit the lighting levels in the format required by the condition.
-----------	---

Kind regards