

27th March 2025

SUBMISSION OF DETAILS FOR THE DISCHARGE OF CONDITIONS

APPLICATION REF: DM/22/2218

APPLICATION DESCRIPTION: REDEVELOPMENT OF SITE TO PROVIDE A DEVELOPMENT OF 50 RETIREMENT LIVING APARTMENTS, ASSOCIATED PARKING, LANDSCAPING AND AMENITY PROVISION. AMENDED PLANS RECEIVED 13/12/2022 REMOVING TOP FLOOR OF COMMUNAL FACILITIES AND ROOFTOP TERRACE AND ALSO SUBMISSION OF A CONSTRUCTION MANAGEMENT PLAN AND SURFACE WATER MANAGEMENT PLAN DURING CONSTRUCTION

At Maxwellton House, Boltro Road, Haywards Heath

CONDITIONS: 6 Materials, 7 Elevation Details, 8 Details, 17 Cycle Store, 18 Solar

Please see comments in **BLUE**:

Cond No.	Subject	Wording of Condition	Detail Submitted
6	Materials	No development shall be carried out above ground slab level unless and until there has been submitted to and approved in writing by the Local Planning Authority a schedule and samples of materials and finishes to be used for external walls and roofs as well as the balconies of the proposed building. The works shall be carried out in accordance with the approved details unless otherwise agreed with the Local Planning Authority.	BOLTRO ROAD EXTERNAL MATERIALS – Material Schedule Sheet As mentioned in an email: the submitted schedule of materials appears to be acceptable. However, the submitted proposed elevations have not been annotated to explain the location / differences to the 3 types of brick and the 2 types of cladding which are proposed to the building. The condition also requires details of materials/finishes to be provided for the balconies. Additionally: - Provide details of the upper PPC metal balustrade system. - Provide details of the other balcony railings - Provide details of the vertical PPC aluminium Louvers - Provide details of the vents - Provide details of privacy screens - Provide details of all the windows/doors including RAL colour and type
7	Elevations	No development shall be carried out above ground slab level unless and until there has been submitted to and approved in writing by the Local Planning Authority a 1:100 scale front elevation showing the position of the light brick panels. The works shall be carried out in accordance with the approved details unless otherwise agreed with the Local Planning Authority.	LSE-2780-04-A0401_Proposed Elevations 01 02 Not Acceptable 1. Annotate all facing materials. 2. In addition, these elevations show a plethora of external vents which were not shown in the originally approved elevations. I can only assume this is related to a lack of suitable solutions for ventilation overall. Please provide plans and sections covering the ventilation requirements to help us understand the changes. Please note this will, however, need separate approval through Building Regulations. As presented, this would have a domino effect on how the elevations look, and the standard of the units within the building which I cover in other points.

8	Brick detailing and Elevation Features	No development shall be carried out above ground slab level unless and until there has been submitted to and approved in writing by the Local Planning Authority 1:20 scale sections and elevations (vignettes) of the following shown in context: • Recess brickwork panels, • Top floor balustrading, • The front entrance canopy, • The solar panels in relation to the parapet upstand on the roof, • A projecting balcony on the front façade featuring the vertical fins and the brickwork frame. The development shall be carried out in accordance with the approved details.	3. The introduction of suspended ceilings, is likely to accommodate ducting for ventilation. This has resulted in windows appearing differently than those shown in the approved elevations from the planning permission. Lowering the ceilings impacts the window proportions, causing them to be divided in half by a middle bar, rather than having the top section taller than the bottom, as originally approved. Also, some windows are still as per approved, which results in overall uncoordinated look. 4. The shadow is not shown from the recessed brick panels, and this looks boxed in. Provide typical 1/20 section. 5. Provide typical window section showing window recess. LSE-2780-04-A0402_Proposed Elevations 03 04 Not delivered and requested in my email of the 19th March LSE-2780-04-A0251_Balcony Stack B – plans 1. The balcony railings are not as per approved glazed balustrades. 2. Drainage system to the balconies is not shown. More details needed to establish how water is drained from balconies to prevent dripping of water to balconies on lower level LSE-2780-04-A-0520_Parapet Section with PV Acceptable LSE-2780-04-A2118_Balcony Stack A - details pg.1 1. Section showing lowered ceilings resulting in floor to ceiling height of 2285mm – explain how this corresponds with the Building Regs 2. Balcony railings details provided are not as per approved and this should be glazed balustrades
---	--	---	--

			3. Drainage system to the balconies is not shown. More details needed to establish how water is drained from balconies to prevent dripping of water to balconies on lower level. We would expect the water from balconies to be redirected to rainwater pipes hidden in the brick columns. 4. Ceiling of the balcony is not acceptable and has to match SVK Fibre Cement cladding used for the ceiling showed in dwg: <i>LSE-2780-04-A2205_Typical 5th Floor Balcony Overhang in Brickwork</i> . Annotate colours in RAL. 5. Flashing/cover to the steel frame is missing and should be applied as shown on approved elevations. Provide details. LSE-2780-04-A2119_Balcony Stack - details pg.2 Please see comments above in relation to LSE-2780-04-A2118_Balcony Stack. A - details pg.1. LSE-2780-04-A2120_Balcony Stack - details pg.1 Please see comments above in relation to LSE-2780-04-A2118_Balcony Stack. PPC Aluminium Fascia please provide a sample of this and explain how this covering will be applied and if it will it be applied to all the balconies. LSE-2780-04-A2121_Balcony Stack B - details pg.2 - Soffit boards are not acceptable. - Metal balustrade is not in line with approved glazed balustrade. LSE-2780-04-A-2202_Typical Parapet Detail in Brickwork with Balustrade on 5th Floor LSE-2780-04-A2205_Typical 5th Floor Balcony Overhang in Brickwork Acceptable. The plans provided show a privacy screen between balconies. Please can a typical elevation be provided detailing how it looks, height and material.
18	Solar	No part of the development shall be first occupied until a detailed 1:20 section and elevation drawings showing a typical solar panel in relation to the roof as well as specifications on the panels have been submitted to and approved in writing by the Local Planning Authority. The development shall only proceed in accordance with the agreed details.	B234352PV - 20231025 - Rev 1 (Roof Installation Plan) Acceptable Panel - Solarwatt Classic H 2.0 Pure 30 405wp (Technical Spec) Acceptable roofwindplusEN - PV - B234594 - Roof Above 5th Floor - 20231025 - Rev 1 (Technical Spec) Acceptable Bauder: LSE-2780-04-A-0207 Roof Plan

			Acceptable
--	--	--	------------