

From: planninginfo@midsussex.gov.uk <planninginfo@midsussex.gov.uk>
Sent: 16 June 2025 17:11:23 UTC+01:00
To: "planninginfo" <planninginfo@midsussex.gov.uk>
Subject: Mid Sussex DC - Online Register - Consultee Comments for Planning Application
DM/25/1467

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 16/06/2025 5:11 PM from Oliver Benson on behalf of Contaminated Land.

Application Summary

Reference:	DM/25/1467
Address:	Land At Old Vicarage Field And The Old Estate Yard Church Road Turners Hill West Sussex RH10 4PA
Proposal:	Demolition of existing buildings and the development of 40 dwellings (including affordable housing) with open space, access, parking, drainage, landscaping and other associated works as well as the creation of a new community car park and replacement parking for Lion Lane residents.
Case Officer:	Rachel Richardson

[Click for further information](#)

Comments Details

The site has had historical use as agricultural land, which may have been used for the storage or disposal of items such as biocides, fuels, animal corpses etc.

Comments: Additionally, within the Southeast Corner of the site, our records indicate that the area was originally part of the fire station and that it transitioned into industrial use circa 1987.

Due to the above, and the size and sensitivity of the proposed development, a phased contaminated land condition should be attached to ensure the site is safely developed for its end use.

Additionally, a discovery strategy should also be attached, so that

in the event that contamination not already identified through the desktop study is found, works stop until such time that a further assessment has been made, and further remediation methods are put in place if needed.

Recommendation: Approval with conditions:

1. Prior to the commencement of development approved by this planning permission (or such other date or stage in development as may be agreed in writing with the Local Planning Authority), the following components of a scheme to deal with the risks associated with contamination of the site, shall each be submitted to and approved, in writing, by the local planning authority:

- a) A preliminary risk assessment which has identified:
 - o all previous uses
 - o potential contaminants associated with those uses
 - o a conceptual model of the site indicating sources, pathways and receptors
 - o potentially unacceptable risks arising from contamination at the site

and unless otherwise agreed in writing by the Local Planning Authority,

b) A site investigation scheme, based on (a) to provide information for a detailed assessment of the risk to all receptors that may be affected, including those off site;

and, unless otherwise agreed in writing by the Local Planning Authority,

c) Based on the site investigation results and the detailed risk assessment (b) an options appraisal and remediation strategy giving full details of the remediation measures required and how they are to be undertaken.

Reason: To ensure that the risks from land contamination to the future users of the land are minimised, and to ensure that the development can be carried out safely without unacceptable risks to workers, neighbours and other offsite receptors.

2. The development hereby permitted shall not be occupied/brought into use until there has been submitted to and approved in writing by the Local Planning Authority a verification plan by a competent person showing that the remediation scheme required and approved has been implemented fully and in accordance with the approved details (unless varied with the written agreement of the Local Planning Authority in advance of implementation). Any requirements for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action shall be identified within the report, and thereafter

maintained.

Reason: To ensure that the risks from land contamination to the future users of the land are minimised, and to ensure that the development can be carried out safely without unacceptable risks to workers, neighbours and other offsite receptors.

3. If during construction, contamination not previously identified is found to be present at the site then no further development (unless otherwise agreed in writing by the LPA), shall be carried out until a method statement identifying, assessing the risk and proposing remediation measures, together with a programme, shall be submitted to and approved in writing by the LPA. The remediation measures shall be carried out as approved and in accordance with the approved programme. If no unexpected contamination is encountered during development works, on completion of works and prior to occupation a letter confirming this should be submitted to the LPA. If unexpected contamination is encountered during development works, on completion of works and prior to occupation, the agreed information, results of investigation and details of any remediation undertaken will be produced to the satisfaction of and approved in writing by the Local Planning Authority.

Reason: To ensure that the risks from land contamination to the future users of the land are minimised, and to ensure that the development can be carried out safely without unacceptable risks to workers, neighbours and other offsite receptors.

Kind regards