

From: Jane Cooper <Jane.Cooper@midsussex.gov.uk>
Sent: 07 August 2026 14:24:30 UTC+01:00
To: "Susan Dubberley" <Susan.Dubberley@midsussex.gov.uk>
Subject: RE: RE:DM/26/1525 Sussex House Perrymount road Haywards Heath (Aldi)

Hi Sue,

Given the clarification provided on the email from Grace dated 03/08/26 I can recommend discharge of condition 6.

Kind regards,

Jane Cooper
Environmental Health Officer
Environmental Health
Tel: +44 (0)1444 477437
Email: jane.cooper@midsussex.gov.uk
Website: www.midsussex.gov.uk

"Working together for a better Mid Sussex"

From: Susan Dubberley <Susan.Dubberley@midsussex.gov.uk>
Sent: 06 August 2026 17:00
To: Jane Cooper <Jane.Cooper@midsussex.gov.uk>
Subject: FW: RE:DM/26/1525 Sussex House Perrymount road Haywards Heath (Aldi)

Hi Jane,

Please find below and attached the latest response from the agent regarding the condition 6.

Kind Regards

Sue Dubberley BA(Hons) Dip TP MRTPI
Senior Planning Officer
Development Management
(01444 477590)

(Please note my working days are Monday to Thursday)

From: Grace Izinyon <graceinzinyon@harrispartnership.com>
Sent: 03 August 2026 10:18
To: Susan Dubberley <Susan.Dubberley@midsussex.gov.uk>
Subject: RE: RE:DM/26/1525 Sussex House Perrymount road Haywards Heath (Aldi)

Hi Susan,

Hope you had a good weekend. Thank you for your email.

Apologies, the site plan at Appendix E of the acoustic report was not the latest revision. I have attached the current version, which will tie up to the plant elevation drawings. Apart from the intentional opening to the south to provide airflow, the enclosure will be continuous from the timber acoustic fence to the paladin fence. The acoustic barrier itself is formed of Jakoustic Absorptive fencing to the specification attached on the previous email and the full build up list is mentioned on drawing 19971-THPK-XX-XX-DA-A-0191 Acoustic Plant. The noise assessment was undertaken based on the designed enclosure, including the southern airflow opening. On that basis, the predicted plant noise level should not exceed the background sound level.

I hope this answered the EHO's queries, but please do let me know if any further detail or clarification is needed.

Kind regards,



Grace Izinyon

Architectural Assistant

T: 01908 211 577

The Harris Partnership Ltd - The Old Rectory, 79 High Street, Newport Pagnell. MK16 8AB

www.harrispartnership.com

Wakefield | Manchester | Milton Keynes | Reading | London | Harrogate | Edinburgh