

From: drainage <drainage@midsussex.gov.uk>
Sent: 17 December 2025 17:16:17 UTC+00:00
To: "Joanne Fisher" <Joanne.Fisher@midsussex.gov.uk>
Cc: "drainage" <drainage@midsussex.gov.uk>
Subject: 2025.12.17 Re: DM/25/1535 - Twinham, Hurst Road, Hassocks

Dear Joanne,

The Flood Risk and Drainage Team have reviewed the updated information and have the following comments.

The stated peak depth is the surcharged depth and not the peak depth of the storage. The half drain time should be calculated from the peak depth.

Upon receipt of this corrected information, we will be able to comment further. For completeness and to ensure it meets the policy checklist this information is required.

Best Wishes

Flood Risk and Drainage Team
Estate Services and Building Control
Mid Sussex District Council
drainage@midsussex.gov.uk