

RE: DM/25/2824




Jane Cooper

To Stefan Galyas

Retention Policy Default 3 year delete (3 years)

Expires on 15/12/2028



Tue 16/12/2025 14:50

Hi Stefan,

As discussed, I need more information to assess the possible impact on nearby residents.

We have received complaints from residents regarding nighttime deliveries at this site, please can the company confirm when this scissor lift is likely to be used. Are there plans to use it during the nighttime (07.00 to 23.00).

The information contained in the submitted report is of limited use. Ideally an assessment in accordance with BS4142 would be required to determine the effect of noise on neighbours during unloading of cages from lorries and transferring them to into the store. The need for a full assessment will depend upon what time of day the proposed scissor lift will be in use.

Please will you request further information from the applicants.

Thanks,

Jane Cooper
Environmental Health Officer
Environmental Health
Tel: +44 (0)1444 477437
Email: jane.cooper@midsussex.gov.uk
Website: www.midsussex.gov.uk