



Tom Andrews
Charles House, 148 Great Charles Street Queensway
Birmingham
West Midlands
B3 3HT

Your ref
24697

Our ref
DSA000052035

Date
10th of March 2026

Contact
Tel 0330 303 0119

Dear Mr Andrews,
Level 1 Capacity Check Enquiry: East Grinstead House.


We have completed the capacity check for the above development site and the results are as follows:

Surface Water

The enquiry has been assessed to determine the capacity available for **0.9 l/s** at manhole reference **TQ38389350 (538989, 138386)**.

There is currently adequate capacity in the local surface water/foul sewerage network to accommodate a surface water flow of **0.9 l/s** for the above development at manhole reference **TQ38389350 (538989, 138386)**.

Although capacity in the surface water network has been identified, in all situations where surface water is being considered for discharge to our network, we require the below hierarchy for surface water to be followed which is reflected in part H3 of the Building Regulations. Whilst reuse does not strictly form part of this hierarchy, Southern Water would encourage the consideration of reuse for new developments.





Guidance on Building Regulations is here: [gov.uk/government/publications/drainage-and-waste-disposal-approved-document-h](https://www.gov.uk/government/publications/drainage-and-waste-disposal-approved-document-h)

We would welcome the opportunity to engage with you on the design for disposal of surface water, with a particular focus on the potential for incorporating Sustainable Drainage Systems (SuDS), for this development at the earliest opportunity and we recommend that civil engineers and landscape architects work together and with Southern Water.

Where a surface water connection to the foul or combined sewer is being considered, this should be agreed by the Lead Local Flood Authority, in consultation with Southern Water.

It should be noted that although the above assessment indicates that there is capacity available for your proposed surface water flows the LLFA (Local Lead Flood Authority) may impose/request that a lower flow is discharged to the public surface water sewer.

If the excess surface water flows are to be attenuated on site, it could have a significant effect on any proposed Sewer Adoption (S104) Agreements. Any attenuation proposals should be agreed before any works are implemented on site. Where capacity is limited/restricted, agreement should be sought if you are to include any highway drainage within your proposals as Southern Water is not obligated to accept highway flows.

Connecting to our network

It should be noted that this information is only a hydraulic assessment of the existing sewerage network and does not grant approval for a connection to the public sewerage system. A formal Sewer Connection (S106) application is required to be completed and approved by Southern Water Services. To make an application visit: developerservices.southernwater.co.uk

Please note the information provided above does not grant approval for any designs/drawings submitted for the capacity analysis. The results quoted above are only valid for 12 months from the date of issue of this letter. **Any revisions in flow rate or alternative point of connection will require a new Pre-Planning Application to be submitted.**

Please get in touch via the Get Connected customer dashboard if you have any queries.

Yours sincerely,

Future Growth Planning Team
Developer Services

southernwater.co.uk/developing-building/planning-your-development