

notes:
light duty covers fmh1, swmh 2, and swmh 3 needs to be medium duty covers
fmh2 steel covers needs further assessment as it cant be opened
swmh1 steel cover handle is broken and cannot be opened
swmh 1 & 2 are assumed surface water
swmh 3 to 6 to be checked and confirmed if surface water

