



Oaklands
Oaklands Road
Haywards Heath
West Sussex
RH16 1SS

Switchboard 01444 458166

DX 300320 Haywards Heath 1
www.midsussex.gov.uk

Stessie Aristide
Connections Surveyor
South Eastern Power Networks
Property And Consents
C/O Energy House
Hazelwick Avenue
Three Bridges
Crawley

CONTACT: Peter Davies
PHONE: 01444 477193
E-MAIL: peter.davies@midsussex.gov.uk
DATE: 8th August 2025

Dear Sir/Madam

Reference: DM/25/1911

Description: To replace the existing 50kVA pole mounted transformer (PMT) attached to pole 616344 with a 100kVA PMT. To upgrade the overhead lines between poles 616344 and 632970 to 95ABC. In addition to the proposed works listed on our letter, we need to install a new stay wire to pole 616344 and potentially replace pole 616344 as part of the works.

Location: Westup Farm Deaks Lane Cuckfield Haywards Heath

I refer to your application received in this office on 28th July 2025 concerning the above site.

The authority does not have any objection to the above works and they may proceed under the terms of the Overhead Line (Exemption) (England and Wales) Regulations 2009.

Mid Sussex District Council does not wish the Secretary of State to consider the application using the full section 37 process under the Electricity Act 1989.

Yours faithfully

Ann Biggs
Assistant Director Planning and Sustainable Economy

NOOHLZ

Planning Services Division

Ann Biggs
Assistant Director Planning and Sustainable Economy

