

From: drainage <drainage@midsussex.gov.uk>
Sent: 28 November 2025 14:14:00 UTC+00:00
To: "Joanne Fisher" <Joanne.Fisher@midsussex.gov.uk>
Cc: "drainage" <drainage@midsussex.gov.uk>
Subject: 2025.11.28 Re: DM/25/1535 - Twinham, 34 Hurst Road, Hassocks, West Sussex

Dear Joanne,

The Flood Risk and Drainage Team have reviewed the information submitted on the 20th November and have the following comments:

The calculations show that water is leaving the system via other means in addition to infiltration. No water should leave the system except through infiltration.

From reviewing the model results, the supplied half drain time for the raingarden does not appear to correlate with the supplied network results.

Upon receipt of this information, we will be able to comment further.

Best Wishes

Flood Risk and Drainage Team
Estate Services and Building Control
Mid Sussex District Council
drainage@midsussex.gov.uk