

From: Irene Fletcher <Irene.Fletcher@midsussex.gov.uk>
Sent: 26 June 2025 15:11:46 UTC+01:00
To: "Joseph Swift" <Joseph.Swift@midsussex.gov.uk>
Subject: RE: DM/25/1127

Hi Joe,

Details are now sufficient to discharge the condition.

Kind Regards,

Irene Fletcher
Tree Officer
Development Management
Mid Sussex District Council
(Mon – Thurs)
www.midsussex.gov.uk

From: Joseph Swift <Joseph.Swift@midsussex.gov.uk>
Sent: 18 June 2025 15:37
To: Irene Fletcher <Irene.Fletcher@midsussex.gov.uk>
Subject: RE: DM/25/1127

Good afternoon Irene,

Following your comments as set out below I have received the attached revised information.

Please can you advise if this is now sufficient to discharge the condition?

Many thanks

Joe

Joseph Swift BA (Hons) MPLAN
Senior Planning Officer (Brookleigh)
01444 477319
joseph.swift@midsussex.gov.uk
www.midsussex.gov.uk



From: Irene Fletcher <Irene.Fletcher@midsussex.gov.uk>

Sent: 11 June 2025 15:24

To: Joseph Swift <Joseph.Swift@midsussex.gov.uk>

Subject: DM/25/1127

Hi Joe,

No actual detailed specification of plant selection has been submitted for the green scheme. This should be specified, as there are a number of plant options shown. I would expect to see Hedera helix or a Hedera helix cultivar. Please can this be clarified and detailed as part of the application.

The method statement itself is satisfactory, but it relates mainly to health and safety issues. I would expect it also to include details of aftercare, particularly watering, for the green screen.

The method statement also advises that it is 'outline' only. As this is a discharge of condition application, this is not acceptable.

Thanks,

Irene

Irene Fletcher
Tree Officer
Development Management
Mid Sussex District Council
(Mon – Thurs)
www.midsussex.gov.uk