

From: Lucy Lloyd <Lucy@thehayassociates.co.uk>
Sent: 10 February 2026 17:16:31 UTC+00:00
To: "Joseph Swift" <Joseph.Swift@midsussex.gov.uk>
Subject: Re: DM/26/0044

Good evening Joseph,

Thank you for bringing this to my attention.

In this case, the maximum illuminance will be 300cd/m2.

Please let me know if you need any further information.

Kind regards,

Lucy Lloyd
Architectural Assistant & Interior Designer



Hay Associates Limited
4100 Park Approach
Thorpe Park
Leeds
LS15 8GB

tel: 0113 880 5500
mob: 07747 678835
email: lucy@thehayassociates.co.uk
web: thehayassociates.co.uk

 Interior Design Institute | GRADUATE

Privacy Policy/Email Disclaimer www.thehayassociates.co.uk/privacy-policy

From: Joseph Swift <Joseph.Swift@midsussex.gov.uk>
Sent: Tuesday, February 10, 2026 4:42 PM
To: Lucy Lloyd <Lucy@thehayassociates.co.uk>
Subject: DM/26/0044

Good afternoon Lucy,

RE: Proposed 1no. standing sign.

AT: Land To The South Of Kings Way, Burgess Hill, RH15 0XP

REFERENCE: DM/26/0044

I have just been reviewing the above mentioned application and I have noticed that the proposed signage is to be illuminated to 1000cd/m2.

Can you confirm that is correct. If so, this exceeds the WSCC illuminated standing advice as set out below:

Light Technical Parameter	Maximum sign illuminance cd/m2				
	Environmental Zones				
Sign Surface Area	E0	E1	E2	E3	E4
0 to <5 m2	0	25	200	300	300
5 to <20 m2	0	0	200	300	300
>20 m2	0	0	100	200	300

This site would fall within the E3 zone, however as you can see the maximum levels is 300cd/m2.

Please can you advise me on how you wish to proceed?

Many thanks

Joseph Swift BA (Hons) MPLAN
Senior Planning Officer (Brookleigh)
01444 477319
Mid Sussex District Council
joseph.swift@midsussex.gov.uk
www.midsussex.gov.uk



Working together for a better Mid Sussex

The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information contained in this email is legally exempt from disclosure, we cannot guarantee that we will not provide the whole or part of this email to a third party making a request for information about the subject matter of this email. This email and any attachments may contain confidential information and is intended only to be seen and used by the named addressees. If you are not the named addressee, any use, disclosure, copying, alteration or forwarding of this email and its attachments is unauthorised. If you have received this email in error please notify the sender immediately by email or by calling +44 (0) 1444 458 166 and remove this email and its attachments from your system. The views expressed within this email and any attachments are not necessarily the views or policies of Mid Sussex District Council. We have taken precautions to minimise the risk of transmitting software viruses, but we advise you to carry out your own virus checks before accessing this email and any attachments. Except where required by law, we shall not be responsible for any damage, loss or liability of any kind suffered in connection with this email and any attachments, or which may result from reliance on the contents of this email and any attachments.