

From: Nicholas Bennett <Nicholas.Bennett@midsussex.gov.uk>
Sent: 15 May 2026 13:33:00 UTC+01:00
To: "Rachel Richardson" <Rachel.Richardson@midsussex.gov.uk>
Subject: DM/26/0766

Hi Rachel

I can't find a consultation on the portal, so these are my comments:

The proposed condenser plant is to replace the existing. As long as the condensers are only used during daytime hours, noise is unlikely to cause any issues. Accordingly:

Conditions -

The external condensers hereby permitted, including any associated plant, shall only be operated between the hours of 07:00 and 19:00 on any day.

Reason – to preserve residential amenity and in accordance with DP29

Thanks

Nick Bennett

Senior Environmental Health Officer | Environmental Protection Team | Environmental Health | Mid
Sussex District Council | Tel: +44 (0)1444 477292 | Email: nicholas.bennett@midsussex.gov.uk



MID SUSSEX
DISTRICT COUNCIL

www.midsussex.gov.uk

‘Working together for a better Mid Sussex’

I am often out of the office on visits. If you require an immediate response please call the office on 01444 477292.
Thank you.