

From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
Sent: 21 September 2026 07:55:51 UTC+01:00
To: "Katherine Williams" <Katherine.Williams@midsussex.gov.uk>
Subject: Discharge of Condition 15 Fire Hydrants - DM/26/1689 Land South Of St Stephens Church Hamsland Horsted Keynes West Sussex

Dear Katherine,

Having viewed the details for the discharge of planning condition 15, providing the fire hydrants indicated on the plan submitted are place, ready for use and West Sussex Fire & Rescue Service are informed they are ready for use the fire hydrant condition raised will be met and can be discharged. Unfortunately, on too many occasions WSFRS are not informed when a FH is ready for adoption, which then puts lives and properties at greater risk in the event of a fire.

Regards
Ian



Ian Stocks

Water & Access Manager - Protection

West Sussex Fire & Rescue Service

Office 0330 222 4499 **Mobile** 07921 291051

Web www.westsussex.gov.uk/fire

Email frs.waterandaccess@westsussex.gov.uk

Bognor Regis Fire Station Fire Station, West Meads Drive, West

LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.
