

From: Nicholas Bennett <Nicholas.Bennett@midsussex.gov.uk>
Sent: 25 August 2026 16:46:25 UTC+01:00
To: "Steven King" <Steven.King@midsussex.gov.uk>
Subject: DM/26/1898 - Discharge of planning conditions 8, 10, 12, 13 and 14 relating to planning application DM/23/2699.

Hi Steve

Am sending responses by email currently due to the technical issues with the portal.
Here is my response for Cond 14 only:

Environmental Protection has no objection to the submitted lighting design, illuminance levels or light spill assessment. However, the submission does not appear to provide details of the measures to ensure the lighting is switched off when not in use, as required by Condition 14. Further details are requested before the condition is discharged.

Thanks

Nick Bennett – S.E.H.O. | [Environmental Protection](#) | [Mid Sussex District Council](#) | 01444 477292