

Mid Sussex District Council
Development Control
Oaklands Oaklands Road
Haywards Heath
West Sussex
RH16 1SS

Our ref: HA/2025/127096/02-L01
Your ref: DM/25/2853
Date: 25 November 2025

Dear Sir/Madam

**DISCHARGE OF CONDITION NO 6 RELATING TO PLANNING APPLICATION
DM/25/1753**

**TANYARD MANOR, HORSTED LANE, SHARPTHORNE, EAST GRINSTEAD,
WEST SUSSEX, RH19 4HY.**

Thank you for consulting the Environment Agency on the above application.
We have reviewed the information as submitted and set out our position below.

Environment Agency position

We have reviewed the submitted details and do not consider that these are sufficient to allow the discharge of condition 6.

Reason(s)

The supplied documents are guidance for the installation. To recommend discharge of this condition for aspects within our remit, we would require the applicant to supply site-specific details on the excavation, the tank, tank surround, associated pipework and monitoring system. Details should be specific to this site and installation rather than the suppliers range of guidelines, to ensure they are suitable at this location.

If you have any queries regarding the above information, please do not hesitate to contact the advisor identified below.

Yours faithfully,

Environment Agency – Solent & South Downs

Sustainable Places Advisor: John Fanning
Direct e-mail: John.Fanning@environment-agency.gov.uk