

From: drainage <drainage@midsussex.gov.uk>
Sent: 19 June 2026 16:32:57 UTC+01:00
To: "Joanne Fisher" <Joanne.Fisher@midsussex.gov.uk>
Cc: "drainage" <drainage@midsussex.gov.uk>
Subject: 2026.06.19 Re: DM/26/0846 - Crabbet Park Equestrian Centre

Dear Joanne,

The flood risk and drainage team have reviewed the submitted information and have the following comments:

- The system should be designed so that the drainage calculations do not show any flooding.
- Evidence using the simple index approach should be utilised to demonstrate that adequate water quality treatment is being achieved.

We cannot see from the information available if Thames Water have been consulted as part of this application. If they were not consulted at the application stage, given that the proposed discharge is to their network, it may be necessary to consult them at this stage. Can you please confirm?

Upon receipt of this additional information, we will be able to comment further. Receipt of the requested additional information does not mean further information will not be requested.

Best Wishes

Flood Risk and Drainage Team
Estate Services and Building Control
Mid Sussex District Council
drainage@midsussex.gov.uk