

From: planninginfo@midsussex.gov.uk <planninginfo@midsussex.gov.uk>
Sent: 20 October 2026 12:31:45 UTC+01:00
To: "planninginfo" <planninginfo@midsussex.gov.uk>
Subject: Mid Sussex DC - Online Register - Consultee Comments for Planning Application
DM/26/2155

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 20/10/2026 12:31 PM from Mr Nick Bennett on behalf of Environmental Protection.

Application Summary

Reference:	DM/26/2155
Address:	Mill Studio Old Hollow Copthorne Crawley West Sussex RH10 4TB
Proposal:	Retention of heat pump
Case Officer:	Tracie Axford

[Click for further information](#)

Comments Details

Comments:	The submitted MCS020 assessment demonstrates compliance with the applicable noise criterion. However, before finalising our consultation response, could the applicant please provide the relevant manufacturer's acoustic data sheet for the proposed unit? This will allow us to verify that the MCS020 calculation has been undertaken using the appropriate sound power value for the installed model.
-----------	--

Kind regards