



from
Southern Water 

Mid Sussex District Council
Oaklands
Oaklands Road
Haywards Heath
West Sussex
RH16 1S

Your ref
DM/25/0827

Our ref
DSA000042691

Date
28th of April 2025

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Outline planning application for the erection of up to 130 dwellings, together with the change of use of an existing barn for a flexible community and/or commercial use, along with associated outdoor space and landscaping, drainage infrastructure, hard and soft landscaping, parking, access and associated works (all matters reserved except for access).

Site: Land East Of Lunce's Hill Fox Hill Haywards Heath West Sussex.

Thank you for your correspondence, please see our comments below regarding the above application.

Completed Capacity Check

There is currently adequate capacity in the local sewerage network to accommodate a foul flow of **1.22 l/s** for the above development at manhole reference **TQ33217802**. Please note that no surface water flows (existing or proposed) can be accommodated within the existing foul sewerage system unless agreed by the Lead Local Flood Authority in consultation with Southern Water, after the hierarchy Part H3 of Building Regulations has been complied with.

Existing Southern Water Assets

Please see the attached extract from Southern Water records showing the approximate position of our existing sewer and water main assets crossing/in the vicinity of the development site. The exact position of the public assets must be determined on site by the applicant in consultation with Southern Water before the layout of the proposed development is finalised.

To get in contact to confirm the exact position of the asset please visit.

https://www.southernwater.co.uk/media/ph4fk3pe/ds-location-of-rising-mains_pb.pdf

For information on required stand-off distances from public sewers please refer to:

<https://www.southernwater.co.uk/media/st5orivm/stand-off-distances.pdf>

Existing Rising Main stand-off distance

The **100 mm** diameter rising main requires a minimum clearance of **3 metres** on either side of the rising main to protect it from construction works and to allow for future access for maintenance. We would recommend using stand-off distances as per our water mains, please refer to: <https://www.southernwater.co.uk/media/st5orjvm/stand-off-distances.pdf>

No development or tree planting should be carried out within **3 metres** of the external edge of the public rising main without consent from Southern Water. All existing infrastructure should be protected during the course of construction works.

Condition: In order to protect public sewers, Southern Water requests that if consent is granted, the following condition is attached to the planning permission; The developer must agree with Southern Water, prior to commencement of the development, the measures to be undertaken to protect the public sewers.

Proposed SuDS

If it is the intention of the developer for Southern Water to adopt the proposed SuDS, the system shall be designed and constructed in line with the Design and Construction Guidance www.water.org.uk/sewerage-sector-guidance-approved-documents/

No Soakaways should be connected to the public surface water sewer.

The supporting documents make reference to drainage using Sustainable Drainage Systems (SuDS). Where SuDS form part of a continuous sewer system, and are not an isolated end of pipe SuDS component, adoption of SuDS will be considered if requested by the developer if they comply with: Design and Construction Guidance (Appendix C), CIRIA guidance and Southern Water SuDS Guidance available here:

<https://www.water.org.uk/sewerage-sector-guidance-approved-documents/>

<https://www.ciria.org/ItemDetail?iProductCode=C753F&Category=FREEPUBS>

<https://www.southernwater.co.uk/media/l4ndl3db/suds-final-080824.pdf>

Where SuDS rely upon facilities which are not adoptable by sewerage undertakers the applicant will need to ensure that arrangements exist for the long-term maintenance of the SuDS facilities. It is critical that the effectiveness of these systems is maintained in perpetuity. Good management will avoid flooding from the proposed surface water system, which may result in the inundation of the foul sewerage system.

Thus, where a SuDS scheme is to be implemented, the drainage details submitted to the Local Planning Authority should:

- Specify the responsibilities of each party for the implementation of the SuDS scheme.
- Specify a timetable for implementation.
- Provide a management and maintenance plan for the lifetime of the development.

This should include the arrangements for adoption by any public authority or statutory undertaker and any other arrangements to secure the operation of the scheme throughout its lifetime. This initial assessment does not prejudice any future assessment or commit to any adoption agreements under Section 104 of the Water Industry Act 1991.

Connection to Public Sewer

Once the location of the existing sewer crossing the vicinity is established, Southern Water will require a formal application for a connection to the public sewer to be made by the applicant or developer. To make an application visit Southern Water's Get Connected service: <https://developerservices.southernwater.co.uk> and please read our New Connections Charging Arrangements documents which are available on our website via the following link: <https://www.southernwater.co.uk/developing-building/connection-charging-arrangements>

We request that should this planning application receive planning approval, the following informative is attached to the consent: Construction of the development shall not commence until details of the proposed means of foul sewerage and surface water disposal have been submitted to and approved in writing by the Local Planning Authority in consultation with Southern Water.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119)

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
southernwater.co.uk/developing-building/planning-your-development