

From: Emma Rivett <Emma.Rivett@midsussex.gov.uk>
Sent: 24 April 2025 07:58:02 UTC+01:00
To: "Caroline Grist" <Caroline.Grist@midsussex.gov.uk>
Subject: DM/25/0709 Plummerden House, Park Lane, Lindfield

Dear Caroline,

I have reviewed the Arboricultural Impact Assessment (AIA) and Tree Constraints Plan and can see that some trees are affected by the proposal.

The AIA mentions a Tree Protection Plan as well as impact on a category A oak with regards to hard surfacing, but I am unable to find an Arboricultural Method Statement or a Tree Protection Plan to ensure that the retained trees are protected. It does briefly refer to the harm being mitigated by permeable materials and hand excavation but I require more detail. Please could this be requested?

Please reconsult me when this further information has been received.

Many thanks.

Emma

Emma Rivett
Assistant Tree Officer-Development Management
www.midsussex.gov.uk

Working together for a better Mid Sussex