

WEST SUSSEX COUNTY COUNCIL  
WEST SUSSEX FIRE AND RESCUE SERVICE

**HYDRANT CONDITION CONSULTATION WITH PLANNING AUTHORITY**

Date: 20.07.2026

To: Steven King

From: Ian Stocks

Planning Ref: DM/26/0577

Address: Land West Of Turners Hill Road And North Of Huntsland Including Hurst Farm Turners Hill Road Crawley Down West Sussex

Description: Outline application (appearance, landscaping, layout and scale reserved), for the demolition of existing buildings and erection of up to 230 dwellings, a care home (use class c2) up to 70 beds, and community facility, and associated infrastructure including new access points off of Turners Hill Road, with associated spine road and car and cycle parking, together with provision of open space, play facilities, utilities infrastructure, surface water drainage features, and associated works. (Additional drainage information received 30/03/26 and transport information received 24/04/26)

Date of visit: N/A

**RECOMMENDATION**

|            |                                            |               |                          |                   |                          |
|------------|--------------------------------------------|---------------|--------------------------|-------------------|--------------------------|
| Advice:    | <input checked="checked" type="checkbox"/> | Modification: | <input type="checkbox"/> | More Information: | <input type="checkbox"/> |
| Objection: | <input type="checkbox"/>                   | No Objection: | <input type="checkbox"/> | Refusal:          | <input type="checkbox"/> |

Total number of hydrants required Unknown

**This application has been dealt with in accordance with the statutory obligation placed upon Fire and Rescue Service by the following act.**

***Fire and Rescue Services Act 2004***

*Part 5, 38: Duty to secure water supply etc.*

*A fire and rescue authority must take all reasonable measures for securing that an adequate supply of water will be available for the authority's use in the event of fire.*

This proposal has been considered by means of desktop study, using the information and plans submitted with this application, in conjunction with other available WSCC mapping and Fire and Rescue Service information. A site visit can be arranged on request.

I refer to your consultation in respect of the above planning application and would provide the following comments:

- 1) Prior to the commencement of this development, details showing the proposed location of the required fire hydrants shall be submitted to and approved in writing by the Local Planning Authority.
- 2) Prior to the first occupation of any new build dwelling forming part of the proposed development, the required fire hydrants shall be fully installed and made operational in the approved location. The fire hydrants shall be maintained thereafter for the lifetime of the development.
- 3) Prior to the first occupation of any of the new build dwelling forming part of the proposed development, they will notify the West Sussex County Council's Fire and Rescue Service that the fire hydrant(s) have been installed and are operational, to ensure that the Fire and Rescue Service are aware that the hydrant(s) is now a usable asset in the event of a fire.

The fire hydrant(s) shall thereafter be maintained as part of the development by the water undertaker at the expense of the Fire and Rescue Service if adopted as part of the public mains supply (Fire Services Act 2004) or by the owner / occupier if the installation is retained as a private network.

As part of the Building Regulations 2004, adequate access for firefighting vehicles and equipment from the public highway must be available and may require additional work on or off site, particularly in very large developments. (BS9999 Section 6: Para 21 & 22) for further information please contact the Fire and Rescue Service.

If a requirement for additional water supply is identified by the Fire and Rescue Service and is subsequently not supplied, there is an increased risk for the Service to control a potential fire. It is therefore recommended that the hydrant condition is implemented.

*Reason: In the interests of amenity and in accordance with Mid Sussex District Plan (2014 – 2031) Key Policies DP18 and DP19 and in accordance with The Fire & Rescue Service Act 2004.*

Ian Stocks

Water and Access Manager

Email: [frs.waterandaccess@westsussex.gov.uk](mailto:frs.waterandaccess@westsussex.gov.uk)