

From: Jane Cooper <Jane.Cooper@midsussex.gov.uk>
Sent: 08 December 2025 16:22:57 UTC+00:00
To: "Stefan Galyas" <Stefan.Galyas@midsussex.gov.uk>
Subject: DM/25/2824

Hi Stefan,

As discussed, I need more information to be able to consider this application.

1. When will the scissor lift be in operation, are there plans to use it early in the morning or during the evening/nighttime period for example.
2. What noise levels are likely from the lift. Depending upon the likely impact of the noise on nearby residents it may be necessary for a BS4142 assessment to be submitted.
3. The elevations are difficult to interpret, but from the plan it looks like deliveries will not be offloaded inside the building as they are now with the existing scissor lift, and I'm concerned that noise might be created when trollies are transported across the yard into the building. Please can the applicant comment on this.

Thanks,

Jane Cooper
Environmental Health Officer
Environmental Health
Tel: +44 (0)1444 477437
Email: jane.cooper@midsussex.gov.uk
Website: www.midsussex.gov.uk



"Working together for a better Mid Sussex"