

From: drainage <drainage@midsussex.gov.uk>
Sent: 29 May 2026 17:32:00 UTC+01:00
To: "Katherine Williams" <Katherine.Williams@midsussex.gov.uk>
Cc: "drainage" <drainage@midsussex.gov.uk>
Subject: 2026.05.29 RE: DM/25/2726 - Gibbshaven Farm, Furnace Farm Road, Furnace Wood

Dear Katherine,

The Flood Risk and Drainage Team have reviewed the updated information and have the following comments:

Infiltration testing is required to be undertaken in the same location as the proposed infiltration feature.

Half drain times for the soakaway should not exceed 24 hours.

Evidence should be provided to confirm that the critical storm duration has been used, including calculations showing that the required storage volume reduces after the 24-hour storm duration.

Upon receipt of this additional information, we will be able to comment further. Receipt of the requested additional information does not mean further information will not be requested.

Best Wishes

Flood Risk and Drainage Team
Estate Services and Building Control
Mid Sussex District Council
drainage@midsussex.gov.uk