

From: Emma Rivett <Emma.Rivett@midsussex.gov.uk>
Sent: 10 July 2026 14:59:40 UTC+01:00
To: "Stefan Galyas" <Stefan.Galyas@midsussex.gov.uk>
Subject: DM/26/1373 0 Hogs Croft, London Road, Albourn

Hi Stefan,

I have had a look at this application and the information provided in relation to trees on the site and find that the Arboricultural Supporting Statement is insufficient. If trees are within 15m of the proposed development, then an Arboricultural Impact Assessment, including an Arboricultural Survey and Tree Constraints Plan is required as a minimum. If there is work within the Root Protection Area of any retained tree, then an Arboricultural Method Statement and Tree Protection Plan is also required.

Please could you request these documents and then reconsult me once you have received them?

Kind regards

Emma

Emma Rivett
Assistant Tree Officer-Development Management
www.midsussex.gov.uk

Working together for a better Mid Sussex