

From: drainage <drainage@midsussex.gov.uk>
Sent: 24 February 2026 07:27:57 UTC+00:00
To: "Anna Tidey" <anna.tidey@midsussex.gov.uk>
Cc: "drainage" <drainage@midsussex.gov.uk>
Subject: 2026.02.24 Re: DM/26/0263 - 35 Mill Green Road Haywards Heath West Sussex RH16 1XQ

Dear Anna,

Thank you for consulting the Flood Risk and Drainage Team on the above application.

We understand the proposed application is for a single storey rear extension.

The site lies within Flood Zone 1 and is therefore at very low risk of fluvial flooding. The Risk of Flooding from Surface Water mapping suggests the site is shown to be at "Very Low" to "High" surface water flood risk. The area at "High" risk of flooding from surface water is associated with a surface water flow path which runs along Mill Green Road.

The proposed extension (built footprint) is located outside of the Flood Zone 3b extent for surface water.

There will be no increase in vulnerability at the site.

The proposed application is a minor development and fits within the EA Standing Advice.

We have no objection to the proposed development on flood risk grounds.

As an advisory, we would suggest the Applicant considers resistance and resilience measures suggested within the EA standing advice and implements any they deem appropriate due to the increased flood risk in the vicinity of this as a residential site (which are classified as 'more vulnerable').

Drainage should be managed via Building Regulations and Building Control, as necessary.

Best Wishes

Flood Risk and Drainage Team
Estate Services and Building Control
Mid Sussex District Council
drainage@midsussex.gov.uk