

From: Jane Cooper <Jane.Cooper@midsussex.gov.uk>
Sent: 27 January 2026 14:09:35 UTC+00:00
To: "Stefan Galyas" <Stefan.Galyas@midsussex.gov.uk>
Subject: DM/25/2884

Hi Stefan,

Please can the applicant confirm that the MCS 020 calculation was done using the highest sound power level of the heat pump, rather than the "low noise mode" level.

Thanks,

Jane Cooper
Environmental Health Officer
Environmental Health
Tel: +44 (0)1444 477437
Email: jane.cooper@midsussex.gov.uk
Website: www.midsussex.gov.uk



MID SUSSEX
DISTRICT COUNCIL

"Working together for a better Mid Sussex"