

From: James Cox <James.Cox@midsussex.gov.uk>
Sent: 27 August 2025 12:55:03 UTC+01:00
To: "Stefan Galyas" <Stefan.Galyas@midsussex.gov.uk>
Subject: DM/25/2049 - Loriner House

Hello Stefan.

I've had a quick look at the proposals and the only comment I feel I should make, is about the size of the window in Bedroom 1. A window to a habitable room, which includes a bedroom should be at least 1/10th of the floor area for lighting and 1/20th of the floor area for ventilation.

Thanks

James Cox

James Cox
Team Leader – Housing Standards
Mid Sussex District Council
Environmental Health
Tel: +44 (0)1444 477306
Email: james.cox@midsussex.gov.uk



'Working together for a better Mid Sussex'