

From: planninginfo@midsussex.gov.uk <planninginfo@midsussex.gov.uk>
Sent: 17 February 2026 17:13:30 UTC+00:00
To: "planninginfo" <planninginfo@midsussex.gov.uk>
Subject: Mid Sussex DC - Online Register - Consultee Comments for Planning Application
DM/26/0130

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 17/02/2026 5:13 PM from Mr Nick Bennett on behalf of Environmental Protection.

Application Summary

Reference:	DM/26/0130
Address:	Land Adjacent To Rowan East Of Turners Hill Road Crawley Down West Sussex
Proposal:	Discharge of planning condition no 16 relating to planning application DM/23/2961.
Case Officer:	Susan Dubberley

[Click for further information](#)

Comments Details

Comments:	Ventilation layout plans and fan details have been submitted. However, the condition requires submission of a scheme that demonstrates that noise levels affecting residents are not intrusive in relation to background noise levels. It does not appear that such a scheme has been submitted. On this basis, discharge is not recommended presently.
-----------	---

Kind regards