



SIMON DENT ASSOCIATES

at Hove
and Gosport

t 0754 658 3150
e simondent@live.co.uk

HORIZONTAL SOAKAWAY CALCULATIONS CIRIA C753 - EQ 25.4 - using FEH 22 rainfall data

PROJECT TITLE:	Gardeners Arms Ardingly		JOB No:	25049
Permeable Area:	1	LOCATION:	Permeable Area 2	DATE: Apr-26

1. FEH Rainfall data	2. Design Inflow	3. Test rate calculations	4. Design Outflow results
Event: 100 year	Roof (m ²): 0	Test pit L: 2.00	a ₅₀ (sq.m): 3.00
CC %: 1.45	Driveway (m ²): 0	Test pit W: 1.00	Inflow (cu.m): 360.00
Index: 10	roads/bays (m ²): 360	Test pit D: 1.00	Outflow (cu.m): 1.00
Urban Creep (%): 0	Total Area (sq.m): 360	Free vol (%): 100	Storage (cu.m): 718.00
		Effective depth: 1.000	
		Infiltration rate (f) (m/s): 4.700E-06	

5. Infiltration system data	6. Infiltration coefficient (q) (m/h)	7. FOS
Length (m): 57.500	Rate (q) provided by SI: 5	
Width (m): 4.80	Calculated Soil Rate (f): 0.016920	
stimated depth (d): 0.000		
Free vol (%): 30		
Inlet IL: 0.000		
diam inlet: 0.100		
q value (m/h): 0.003		
Calculated base: -0.249		
Top of s/away: 0.135		


Summary of designer's sizes for chosen D min duration for 100 year storm							
L	W	d	Ab	Ad	P	R	n
57.50	4.80	0.000	276.00	360.00	124.60	1.30	0.30

Soakaway calculations are based on BRE 365 infiltration results and the calculated method shown in CIRIA document C697 & C753 and uses FEH 22 rainfall data. The rainfall depths are factored by the climate change growth factor chases. The porosity rate is further factored for safety to suit risk from long term siltting. Always refer to the project construction detail sheets 200 or 201 for the soakaway or permeable pavement make-up and the main general arrangement (GA) showing the size, levels and position of the soakaway.

Calculations used are derived from CIRIA document C753 - SUDS manual Eq 25.4

D (Hrs)	mm	i (m/h)	a	b	h _{max}
0.25	27.05	0.1569	-131.73	0.005092	0.1676
0.50	36.37	0.1055	-87.83	0.005092	0.2234
1.00	46.78	0.0678	-55.70	0.005092	0.2829
2.00	56.52	0.0410	-32.77	0.005092	0.3321
4.00	66.65	0.0242	-18.41	0.005092	0.3713
6.00	72.56	0.0175	-12.76	0.005092	0.3839
10.00	80.05	0.0116	-7.69	0.005092	0.3820
24.00	92.26	0.0056	-2.54	0.005092	0.2927
36.00	98.80	0.0040	-1.18	0.005092	0.1981
48.00	104.26	0.0031	-0.47	0.005092	0.1028
60.00	109.20	0.0026	-0.04	0.005092	0.0100
72.00	113.80	0.0023	0.26	0.005092	-0.0793
84.00	118.16	0.0020	0.47	0.005092	-0.1649
96.00	122.36	0.0018	0.64	0.005092	-0.2464

MAX HEIGHT (H_{max}): 0.3839



Time to empty	
H _{max} :	0.3839
R:	1.30
Time to empty (hrs):	1439
Recalculated q (m/h):	0.00212425
Equivalent f rate:	0.00000059
EMPTY TIME IS GREATER THAN 24 HOURS SEE REQUIRED q ABOVE	