

From: planninginfo@midsussex.gov.uk <planninginfo@midsussex.gov.uk>
Sent: 02 June 2026 14:06:46 UTC+01:00
To: "planninginfo" <planninginfo@midsussex.gov.uk>
Subject: Mid Sussex DC - Online Register - Consultee Comments for Planning Application
DM/26/1090

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 02/06/2026 2:06 PM from Mr Nick Bennett on behalf of Environmental Protection.

Application Summary

Reference:	DM/26/1090
Address:	Francis Court Borers Arms Road Copthorne Crawley West Sussex RH10 3LQ
Proposal:	Discharge of condition nos. 21 and 26 relating to planning application DM/23/2360
Case Officer:	Susan Dubberley

[Click for further information](#)

Comments Details

Comments:	The submitted acoustic report demonstrates that, subject to installation of the specified 2.5 m acoustic barrier/enclosure with absorptive lining, the proposed plant will achieve the required noise levels. Accordingly, discharge is recommended.
-----------	--

Kind regards